



CERT

certificate of conformity

OMS-Konformitätsbescheinigung

OG-4467CS0474

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	smart metering components <i>Smart-Metering Komponenten</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Landis+Gyr GmbH Humboldtstraße 64, D-90459 Nürnberg
Distributor <i>Vertreiber</i>	Landis+Gyr GmbH Humboldtstraße 64, D-90459 Nürnberg
Product Category <i>Produktart</i>	OMS-components: Wireless M-Bus (4467)
Product Description <i>Produktbezeichnung</i>	OMS interface for ultrasonic heat and cooling meters
Model <i>Modell</i>	T550 (UH50)
Test Reports <i>Prüfberichte</i>	laboratory control test: 21-00154-KP02-476 from 21.01.2022 (EBI) type testing: 17/256/4166/203 from 20.11.2017 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DVGW G 5484 (01.09.2016) DVGW CERT ZP 4400 (13.12.2017)

Date of Expiry / File No. 20.11.2027 / 22-0288-GOV
Ablaufdatum / AZ

04.07.2022 Kö A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com

info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
T550	OMS-interface: T1 Protocol: M-Bus Transmission frequency: 869,95 MHz	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

The counter and metering system were not part of the type testing.

The tests refers solely to the examination of the wM-Bus acc. to the Open Metering System Conformance Test; Volume 1-4; Generation 4 (2016)

Typ: 0x04

Encryption mode: 7

Transmission rate: 16s

Installation telegram: non

Static telegram: non

Temperature range: +0°C ... +55°C

Power supply: battery

R&TTE-authorization: TR-73605-07849-11 (Edition 1) (TÜV Süd Product Service GmbH)